

ATTENTION

This room is protected with a clean agent gaseous fire extinguishing system.

To be effective in a fire emergency the fire suppression agent must be retained in the room.

Upon installation of this system, all doors were equipped with automatic closers, weather stripping and floor seals; all cables and conduits leading in or out of the room were sealed (including those above the ceiling or under the raised floor); and all leaks or cracks were sealed. As required, the room was tested per NFPA 2001, 2000 edition, Appendix C, Enclosure Integrity Procedure to assure it was properly sealed to retain the fire suppression agent.

For the safety of the occupants and equipment in this room:

1. Doors must not be blocked open.
2. All weather stripping and seals must be maintained in good operating condition.
3. Any new cables or conduits leading in or out of the room must be caulked and sealed.
4. Any holes or penetrations through the walls must be repaired and sealed.

To assure the sealing integrity of this room, NFPA 2001, 2000 edition, Section 4-4 requires an annual inspection and possible retesting of this room.

Test results:

Date: **May 15, 2002**

Leakage Area: **2.679 sq m**

Minimum Hold Height: **8.00 m**

Hold Time: **12.52 minutes**

Next Inspection due one year from Test Date.

For more information or to schedule an inspection contact:

Fire Safety Technology

P.O. Box 1063

Severna Park, MD 21146

Phone 410-647-8303

Fax 410-647-7066

mail@firesafetytech.com

www.firesafetytech.com